

EPA Region 1 Annual Pretreatment Report Summary Sheet December 2021

POTW Name:	<input type="text" value="South Hadley Wastewater Treatment Plant"/>		
NPDES Permit #:	<input type="text" value="MA0100455"/>		
Pretreatment Report Period Start Date:	<input type="text" value="January 1, 2021"/>		
Pretreatment Report Period End Date:	<input type="text" value="December 31, 2021"/>		
# of Significant Industrial Users (SIUs):	<input type="text" value="0"/>		
# of SIUs Without Control Mechanisms:	<input type="text" value="0"/>		
# of SIUs not Inspected:	<input type="text" value="0"/>		
# of SIUs not Sampled:	<input type="text" value="0"/>		
# of SIUs in Significant Noncompliance (SNC) with Pretreatment Standards:	<input type="text" value="0"/>		
# of SIUs in SNC with Reporting Requirements:	<input type="text" value="0"/>		
# of SIUs in SNC with Pretreatment Compliance Schedule:	<input type="text" value="0"/>		
# of SIUs in SNC Published in Newspaper:	<input type="text" value="0"/>		
# of SIUs with Compliance Schedules:	<input type="text" value="0"/>		
# of Violation Notices Issued to SIUs:	<input type="text" value="0"/>		
# of Administrative Orders Issued to SIUs:	<input type="text" value="0"/>		
# of Civil Suits Filed Against SIUs:	<input type="text" value="0"/>		
# of Criminal Suits Filed Against SIUs:	<input type="text" value="0"/>		
# of Categorical Industrial Users (CIUs):	<input type="text" value="0"/>		
# of CIUs in SNC:	<input type="text" value="0"/>		

Penalties

Total Dollar Amount of Penalties Collected

\$ 0

of IUs from which Penalties have been collected:

0

Local Limits

Date of Most Recent Technical
Evaluation of Local Limits:

Submitted to EPA 4/20/13

Date of Most Recent Adoption of
Technically Based Local Limits:

December 1, 1995

Pollutant	Limit (mg/l)	MAHL (lb/day)
Cadmium	0.028	0.2
Lead	2.13	6.8
Mercury	0.016	0.081
Titanium	11.15	17.5
Heptachlor	0.003	0.059
Toluene	2.04	1226
TSS	1500	